



## SPILL RESPONSE PLAN

**Seasons Corner Market Gasoline Station**  
91 Lowell Road  
Hudson, NH 03051

June 25, 2024

## Purpose

This plan is prepared to provide a written plan of spill response procedures for the Colbea Enterprises LLC (Colbea) facility at 91 Lowell Road in Hudson, New Hampshire.

## Site Description

The facility consists of a single-story, wood framed building with a basement and a canopied dispenser island with six multiproduct gasoline dispensers for retail sales of gasoline. A Seasons Market convenience store and coffee shop is located within the station building with an attached drive thru and car wash.

The site contains two 15,000-gallon Underground Storage Tanks (USTs), one 15,000-gallon regular gasoline and one 15,000-gallon split (9,000 gallon premium and 6,000-gallon diesel).

## Facility Details

### **Facility Location:**

91 Lowell Road  
Hudson, New Hampshire 03051  
Phone # - TBD

### **Property Owner and Operator:**

Colbea Enterprises, LLC  
695 George Washington Highway  
Lincoln, Rhode Island 02865

### **Designated Contact:**

Barbara Therrien, Regional Manager  
Phone Number - 413-222-6196

Kevin Fernandes - Maintenance Manager  
401-368-7599

Eric Simpson - Env Program Manager  
508-298-8686

### **Hospital Location:**

St. Joseph Hospital  
172 Kinsley Street  
603-882-3000

### **Fire Department:**

Hudson Fire Department  
Non-Emergency - 603-886-6021

## Spill Response Procedures

In the event of a product spill at the facility, the following action should be taken:

1. Activate Emergency Dispenser Shut Off
2. If more than 5 gallons contact Hudson Fire Department (911) then contact Colbea Personnel (**Step 7**), if less than 5 gallons contact Colbea Personnel (**Step 7**).
3. Secure spill area to prevent customers from spreading the spill or coming in contact with impacted area.
4. Turn off all vehicle engines, do not attempt to start engines.
5. Contain spillage with absorbent materials, sand, soil, pads, etc. to stop movement of spilled material or dam to contain spill in immediate area. Try to prevent spills from entering any of the site catch basins or any other permeable surface (grass or landscaped areas).
6. In case of fire, contact Hudson Fire Department (911). Do NOT allow public to fight fire. If fire is at fueling islands and the dry chemical system has not automatically released, manually activate the system.
7. Notify Regional Manager, Maintenance Manager, and Environmental Program Manager.